



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No.: MCPHL/25/ 4242

Date: 15.12.2025

Ref. No. : 11/2025/KRK/MC/595/2025	Sample Details	Date & Time
Dated : 11.12.2025		
Issued to : The Principal Kids 'R' Kids Secondary School Sec-42-C, Chandigarh	Collected By : Laboratory Staff	Collection Date : 12.12.2025
Location : From School tap of Kids R Kids Secondary School Sec-42-C, Chandigarh	Collection Date : 09:00 a.m.	Received at Lab : 09:20 a.m.
Packing : Polypropylene and glass bottle		

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.70
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.9
5	Total Dissolved Solids	<500	mg/l	143
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	92
8	Total Hardness (as CaCO ₃)	<200	mg/l	86
9	Chlorides (as Cl)	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	(Excellent)

Payment received vide receipt No. 12/2025-26/290509, dated 11.12.2025, amount Rs.-3300/-

Note: - Water sample is found "POTABLE"

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/25/-----

Dated: 15.12.2025

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)


(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)
(NO OBJECTION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2026/ 885

Dated:- 27/1/26

It is certified that an inspection team headed by Sh Vijay Kumar, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Kids R Kids School, Sector 42-C, Chandigarh on 15-12-2025 and mentioned in inspection report that Kids R Kids School, Sector 42-C, Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. India.

The above Certificate is valid for a period of One-year w.e.f 15.12.2025 (i.e. Water Sampling Date).


Medical Officer of Health
Municipal Corporation
Chandigarh

To

③ Kids R Kids School,
Sector 42-C,
Chandigarh